

**GOVERNMENT OF ANDHRA PRADESH**  
**STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT**

From :  
The Director General,  
State Disaster Response and Fire Services,  
Andhra Pradesh, Vijayawada.

To:  
The District Educational Officer,  
East Godavari District.

**Re.No.5206/EG/RFO/2018, Dt: -12-2022 04-01-2023**

Sub: A.P. State Disaster Response and Fire Services Department-MSB Section-Issuance of Periodical Occupancy Renewal Certificate to M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District -Regarding.

- Ref:
1. Occupancy NOC Rc.No.5206/EG/RFO/2018, Dt:18-11-2022 of Regional Fire Officer, Eastern Region, Vijayawada.
  2. G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated:13.08.2021.
  3. G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated:25.10.2021.
  4. Application for Renewal NOC of M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District .
  5. This Office Memo Rc.No.5206/EG/RFO/2018 Dt:18-11-2022.
  6. Inspection Committee Report Rc.No.80/SFO/RCVM/2022 Dt:13-12-2022.

<< 0 >>

The Management of M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District has requested to issue Periodical Occupancy Renewal Certificate.

2) The No Objection Certificate for Occupancy was issued vide reference 1<sup>st</sup> cited to the existing building of M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District with Ground + 03 Upper Floors with a Height of 12.75 Mtrs., with Built-up area of 4572.58 Sq.Mtrs., for Educational Occupancy..

3) In view of the above, based on the Inspection Committee Report, the Periodical Occupancy Renewal Certificate is issued to the existing building of M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District with Ground + 03 Upper Floors with a Height of 12.75 Mtrs., with Built-up area of 4572.58 Sq.Mtrs., for Educational Occupancy, subject to the following conditions.

| Sl.No. | As Builder   | As Occupant  | As Security personnel   |
|--------|--|--|---|
| 1.     | All the fire protection arrangements shall be maintained in good repair as seen during inspection.   | All the escape / exit roots shall not be kept locked / blocked or encroached.          | All the occupants must know the correct method of operation of the fire fighting system installed             |
| 2.     | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management. | All occupants shall be trained to operate the fire safety equipments during emergency. | Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months. |

(Contd....2p)

  
Principal,  
**RAJAMAHENDRI  
INTERNATIONAL SCHOOL  
RAJAMAHENDRAVARAM**

  
Correspondent,  
**RAJAMAHENDRI  
INTERNATIONAL SCHOOL  
RAJAMAHENDRAVARAM**

| S.No. | As Builder  | As Occupant  | As Security personnel  |
|-------|---|--|--|
| 3.    | Addition / alteration, if any in the building may be verified by building authority.  | Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.  | All security personnel shall be trained to operate the fire safety equipments during emergency.  |
| 4.    | This Periodical Occupancy Renewal Certificate is only from Fire Safety Point of View. | Raise the alarm If the fire cannot be controlled, evacuate the area completely at once with nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling it. If not, takes all steps to isolate the area by closing doors and windows. |


5) The Management shall ensure the following conditions:

- i. The Management is responsible for all risks involved in case of Fire Accident.
- ii. This Periodical Occupancy Renewal Certificate is given based on the Self Certification, Documents and Drawings provided by the Applicant. The Management confirms that the information provided and the Documents and Drawings submitted are correct. Any deviation noticed will lead to cancellation of NOC without any notice.
- iii. The permission accorded does not confer any ownership rights. If it is found that the information furnished is false and fabricated, the permission will be revoked at any stage and the Applicant will be liable for criminal prosecution as per IPC.

6) This Periodical Occupancy Renewal Certificate is valid for a period of Five (05) years from the date of issue of this NOC to the management of M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District. The Owner/ Occupier/ Builder/ Management concerned of the Building shall submit Affidavit/ Self Declaration/ Certification with regard to working condition of above Fire Safety system and Electrical Safety Compliance report every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises.

7) It is the responsibility of the Builder to maintain the Fire Safety equipment in good working condition at all times and apply for next Periodical Occupancy Renewal Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated:13.08.2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.

Yours faithfully,




Director General  
State Disaster Response and Fire Services,  
Andhra Pradesh, Vijayawada.

Copy to the M/s Rajamahendri International School (Rajamahendri Educational Society), RS.No:648/1 & 648/2, Opp.Sampatnagar Electrical Sub Station, Bommuru to Kesavaram road, Rajamahendravaram, East Godavari District.

Copy to the Regional Fire Officer, Eastern Region, Vijayawada.

Copy to the District Disaster Response & Fire Officer, East Godavari District.



Principal  
RAJAMAHENDRI  
INTERNATIONAL SCHOOL  
RAJAMAHENDRAVARAM



Correspondent  
RAJAMAHENDRI  
INTERNATIONAL SCHOOL  
RAJAMAHENDRAVARAM